


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Ref. No.

Dated: 27/11/2025

It is certified that an inspection team headed by Dr. Md. Harun, Medical Officer Incharge from Primary Health Centre, Dildarnagar, Ghazipur inspected the **Sunbeam School Dildarnagar**, Village - Dehwal, Dildarnagar, Ghazipur, Uttar Pradesh on 27/11/2025 and on the basis of Water Test Report (Attached) bearing no **GZP/DW/25/11/165** dated 21/11/2025 of **District Level Water Analysis Laboratory, Uttar Pradesh Jal Nigam (Rural) Ghazipur, 233001** (PHED Lab) certified that the **Sunbeam School Dildarnagar** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Six months

Signature with Seal: 

Name : Dr. Md. Harun

Designation : MO

Name & Address of the Office / Department:

Dr. Md. Harun
Vill - Usia, Post - Usia
Dist - Ghazipur, State - U.P.

To
The Principal/Manager
Sunbeam School Dildarnagar
Village - Dehwal, Dildarnagar,
Ghazipur, Uttar Pradesh

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Manager
Sunbeam School
Dildarnagar


PRINCIPAL
SUNBEAM SCHOOL
DILDARNAGAR-GHAZIPUR



TEST REPORT


District Level Water Analysis Laboratory,

Uttar Pradesh Jal Nigam, (Rural), Ghazipur, 233001



TC-12315

Report No.	GZP/DW/25/11/165	Date:-	21.11.2025	Page No.	1/2	
Customer Name	M/S. SUNBEAM SCHOOL					
Office Name and Address	DEHWAL, DILDARNAGAR, GHAZIPUR -232326					
Ref. Letter No. & Date						
Basic details of sample						
District	Ghazipur	Block	Bhadaura			
Gram Panchayat	Dildarnagar	Village	Dehwal			
Habitation	Dchwal	Location/Site Name	Dchwal			
Water Source	D.W	Sample No.	287			
Quality of Sample (ml)	2 Litre	Date Of S.C.	17.11.2025			
Receiving Date	17.11.2025	S. Collector	D.K Shaw			
Sample Depositor	Sanjay	Sampling Method	IS Method			
Analysis Start Date	17.11.2025	Analysis Completion Date	21.11.2025			
Temperature	24.6°C	Relative Humidity	51.4%			
Technical Data of Analysis						
S. No.	Analyzed parameters	Units	Observed Value	Specified Values as Per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	7.81	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
2	Turbidity	NTU	3.23	1	5	IS 3025 (Part 10): 2017
3	TDS	Mg/L	273.00	500	2000	IS 3025 (Part 16): 2023
4	Chloride	Mg/L	52.98	250	1000	IS 3025 (Part 32): 2019
5	Total Alkalinity	Mg/L	128.00	200	600	IS 3025 (Part 23): 2023
6	Total Hardness	Mg/L	144.00	200	600	IS 3025 (Part 21): 2019
7	Calcium (as Ca)	Mg/L	80.00	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg)	Mg/L	15.55	30	100	IS 3025 (Part 46): 2023
Note:-						
1. This certificate refers only to the particular sample (S) submitted for testing.						
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.						
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue						
(Sanjay Kumar) Prepared by			(Anshu Yadav) Reviewed by			
Laboratory Contact details-Email ID- upjnldistrictlabgzp@gmail.com .						
End of the Report						



Manager
Sunbeam School
Dildarnagar

D.K Shaw
PRINCIPAL
SUNBEAM SCHOOL
DILDARNAGAR-GHAZIPUR



TEST REPORT

District Level Water Analysis Laboratory,

Uttar Pradesh Jal Nigam, (Rural), Ghazipur, 233001



TC-12315

Report No.	GZP/DW/25/H/165	Date:-	21.11.2025	Page No.	1/2
Customer Name	M/S. SUNBEAM SCHOOL				
Office Name and Address	DEHWAL, DILDARNAGAR, GHAZIPUR -232326				
Ref. Letter No. & Date					

Basic details of sample

District	Ghazipur	Block	Bhadaura
Gram Panchayat	Dildarnagar	Village	Dehwal
Habitation	Dehwal	Location/Site Name	Dehwal
Water Source	D.W	Sample No.	135
Quality of Sample (ml)	2 Litre	Date Of S.C.	17.11.2025
Receiving Date	17.11.2025	S. Collector	D.K Shaw
Sample Depositor	Sanjay	Sampling Method	IS Method
Analysis Start Date	17.11.2025	Analysis Completion Date	21.11.2025
Temperature	24.6°C	Relative Humidity	51.4%


Technical Data of Analysis

S. No.	Analyzed parameters	Units	Observed Value	Specified Values as Per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	7.81	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
2	Turbidity	NTU	3.23	1	5	IS 3025 (Part 10): 2017
3	TDS	Mg/L	273.00	500	2000	IS 3025 (Part 16): 2023
4	Chloride	Mg/L	52.98	250	1000	IS 3025 (Part 32): 2019
5	Total Alkalinity	Mg/L	128.00	200	600	IS 3025 (Part 23): 2023
6	Total Hardness	Mg/L	144.00	200	600	IS 3025 (Part 21): 2019
7	Calcium (as Ca)	Mg/L	80.00	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg)	Mg/L	15.55	30	100	IS 3025 (Part 46): 2023

- Note: - 1. This certificate refers only to the particular sample (S) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue

(Sanjay Kumar)
Prepared by

(Anshu Yadav)
Reviewed by



Laboratory Contact details-Email ID- upjldistrictlabgza@gmail.com.

End of the Report

Manager
Sunbeam School
Dildarnagar

Principal
Sunbeam School
Dildarnagar-Ghazipur